


Plugging of Large Diameter/Hand Dug Wells (Exception)

Original Ground Level



2'-3'
Alternative
Cement Cap

* Well still has water, we recommend disinfection before plugging operations

* If well has debris, it should be cleaned out before plugging operations.

Backfill well with compacted clay or caliche to surface.
Leave mounded as to drain water runoff away.